

CERTIFICATE of Conformity



Certificate No.: MK 69241917 0001

Test Report No.: 28207191 002

Certificate Holder: VENTILATION SYSTEMS PrJSC
1, Mikhaila Kotzubinskiego str.
UA-01030 Kiev
Ukraine

Manufacturer: VENTILATION SYSTEMS PrJSC
1, Mikhaila Kotzubinskiego str.
UA-01030 Kiev
Ukraine

Product: Room heater

Identification: Type designation: MPA 800 E1 Rated power input: 3,55kW


Trade mark: VENTS
Rated voltage: 230V, 50Hz
Protection class: I
Degree of protection: IP22

Tested according to: EN 60335-1:2002+A1+A11+A2+A12+A13+A14
EN 60335-2-30:2003+A1+A2
EN 62233:2008

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:

Budapest, 2012.04.23



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu
IT_07-D-Pe_4_0