

CERTIFICATE of Conformity



Certificate No.: MK 69241487 0002

Test Report No.: 28202351 005

Certificate Holder: VENTILATION SYSTEMS PrJSC
1, Mikhaïla Kotzubinskïego str.
UA-01030 Kiev
Ukraine

Manufacturer: VENTILATION SYSTEMS PrJSC
36, 40-richchya Zhovtnya str.,
UA-08150 Boyarka, Kiev region
Ukraine

Product: Axial fans

Identification:

Type designation:	Rated power input:
100 Mxyz , 100 Mxyz L	20W
125 Mxyz , 125 Mxyz L	22W
150 Mxyz , 150 Mxyz L	26W


Rated voltage: 220-240V~, 50Hz
Protection class: II
Schutzart/Degree of protection: IP24
Wo/where xyz: blank; V; T; TH; VT; VTH; TP

Tested according to: EN 60335-1:2002+A1+A11+A2+A12+A13+A14
EN 60335-2-80:2003+A1+A2
EN 62233:2008

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:

Budapest, 2011.12.20



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu
IT_07-D-Pe_4_0